



Priyanshi Fire Services

We aim to give fire protection



Priyanshi Fire Services
We aim to give fire protection

About Us

Fire is an unforeseen hazard that can spread rapidly, cause damage to property and lead to injuries or loss of lives. P.G. Fire Protection Products aim to contain a fire and prevent the spread of fire, smoke and fumes.

At Priyanshi Fire Services, through our expertise and internationally accepted fire protection products & systems, we aim to be a leading fire protection company offering a wide range of fire stop products. We are committed to serving humanity by spreading awareness on the benefits of fire safety measures to create a safer environment.

Our Vision

- Special focus and emphasis on delivering quality products and services to our clients.
- Excel in safe working.
- Be a compulsory choice of our Customers.
- Ensure judicious usage of resources and environmental upkeep.
- Keep growing together.

Our Mision

- Special focus and emphasis on delivering quality products and services to our clients.
- Excel in safe working.
- Be a compulsory choice of our Customers.
- Ensure judicious usage of resources and environmental upkeep.
- Keep growing together.

**DRY POWDER STORED
PRESSURE TYPE
FIRE EXTINGUISHER**

**TECHNICAL
SPECIFICATIONS -
ABC STORED PRESSURE**



MODEL	PRFS A1/A2	PRFS A4 /A6	PRFS A9
Capacity	1/2 kg.	4/6 kg.	9 kg.
Confirming IS No.	15683	15683	15683
Fire Rating	1A,8B /1A,13B,	2A,21B / 3A,34B	4A,55B
Operating Temperature	-20° C To + 55° C	-20° C To + 55° C	-20° C To + 55° C
Min. Jet Length (in mtrs)	2Mtrs.	2Mtrs.	2Mtrs.
Discharge Percentage Min.	85%	85%	85%
Discharge Time Min	8 / 13 Seconds	13 Seconds	13 Seconds
Charge Pressure	15 kgf / cm ²	15 kgf / cm ²	15 kgf / cm ²
Test Pressure	35 Kgf / cm ²	35 Kgf / cm ²	35 Kgf / cm ²
Operating Valves	Squeeze Grip Type	Squeeze Grip Type	Squeeze Grip Type
Extinguisher Media	Dry Powder 14609/4308	Dry Powder 14609/4308	Dry Powder 14609/4308
Expellant	Dry Nitrogen	Dry Nitrogen	Dry Nitrogen
Anti Corrosive Treatment	Phosphating (7 Tanks)	Phosphating (7 Tanks)	Phosphating (7 Tanks)
Painting	Epoxy Polyester Powder Coating	Epoxy Polyester Powder Coating	Epoxy Polyester Powder Coating
Tare Weight (Approx.)	1/1.4 kg.	2.3/3 kg.	5.1 kg.
Gross Weight (Approx.)	2/3.4 kgs.	6.3/9 kgs.	14.1 kgs.

**STORED PRESSURE
TYPE FIRE
EXTINGUISHER**

**TECHNICAL
SPECIFICATIONS -
BC CARTRIDGE TYPE**



MODEL	PRFS A4	PRFS A6	PRFS A9
Capacity	4 kg.	6 kg.	9 kg.
Confirming IS No.	15683	15683	15683
Fire Rating	34B	34B	34B
Operating Temperature	-20° C To + 55° C	-20° C To + 55° C	-20° C To + 55° C
Min. Jet Length (in mtrs)	4Mtrs.	4Mtrs.	6Mtrs.
Discharge Percentage Min.	85%	85%	85%
Discharge Time Min	13 Seconds	13 Seconds	13 Seconds
Charge Pressure	15 kgf / cm ²	15 kgf / cm ²	15 kgf / cm ²
Test Pressure	35 Kgf / cm ²	35 Kgf / cm ²	35 Kgf / cm ²
Operating Valves	Squeeze Grip Type	Squeeze Grip Type	Squeeze Grip Type
Extinguisher Media	Dry Powder 4308/14609	Dry Powder 4308/14609	Dry Powder 4308/14609
Expellant	Co2	Co2	Co2
Anti Corrosive Treatment	Phosphating (7 Tanks)	Phosphating (7 Tanks)	Phosphating (7 Tanks)
Painting	Epoxy Polyester Powder Coating	Epoxy Polyester Powder Coating	Epoxy Polyester Powder Coating
Tare Weight (Approx.)	4 kg.	4.6 kg.	7.3 kg.
Gross Weight (Approx.)	8 kgs.	10.6 kgs.	16.3 kgs.



**Co2TYPE
FIRE EXTINGUISHER**

**TECHNICAL
SPECIFICATIONS**



MODEL	PRFS Co2 2/3	PRFS Co2 4.5/6.5	PRFS Co2 9/22.5
Capacity	2/3 kg.	4.5/6.5 kg.	9 /22.5 kg.
Confirming IS No.	15683	15683	15683
Fire Rating	8/13B	2A,21B/3A,34B	4A,55B
Operating Temperature	-30° C To + 55° C	-30° C To + 55° C	-20° C To + 55° C
Min. Jet Length (in mtrs)	2Mtrs.	2Mtrs.	2Mtrs.
Discharge Percentage Min.	95%	95%	85%
Discharge Time Min	8 Seconds	8/10-20 Seconds	15-36/20-60 Seconds
Cylinder	Seamless IS : 7285	Seamless IS : 7285	Seamless IS : 7285
Test Pressure	250 Kgf/cm ²	250 Kgf/cm ²	250 Kgf/cm ²
Operating Valves	Squeeze Grip/Wheel Type	Squeeze Grip/Wheel Type	Wheel Type
Extinguisher Media	Co2 Gas IS 15222	Co2 Gas IS 15222	Co2 Gas IS 15222
Expellant	Self	Self	Self
Operating Position	--	-	-
Painting	Enamel Paint IS : 5 Shade 536/538	Enamel Paint IS : 5 Shade 536/538	Enamel Paint IS : 5 Shade 536/538
Tare Weight (Approx.)	6.2/9.4 kgs.	13.3/17.7 kgs.	23.5/55.5 kgs.
Gross Weight (Approx.)	8.2/12.4 kgs.	17.8/24.2 kgs.	32.5/78 kgs.

**MECHANICALFOAM
(STOREDPRESSURE)
FIREEXTINGUISHER**

**TECHNICAL
SPECIFICATIONS-
StoredPressure/
CartridgeType**



MODEL	PRFS M6/9	PRFS M 6/9	PRFS M 50
Capacity	6/9 ltrs.	6/9 kg.	50 kg.
Confirming IS No.	15683	15683	16018
Fire Rating	2A, 34B/4A, 89B	2A, 34B/3A, 34B	20A, 2333B
Operating Temperature	+5 C To + 55°C	-20° C To + 55° C	-20° C To + 55° C
Min. Jet Length (in mtrs)	6Mtrs.	6Mtrs.	10Mtrs.
Discharge Percentage Min.	95%	95%	95%
Discharge Time Min	13 Seconds	13 Seconds	60 - 180 Seconds
Charge Pressure	-	-	-
Test Pressure	35 Kgf/cm ²	35 Kgf/cm ²	30 Kgf/cm ²
Operating Valves	Squeeze Grip Type	Squeeze Grip Type	Conventional
Extinguisher Media	AFFF IS : 4989	AFFF IS : 4989	AFFF IS : 4989
Expellant	Dry Nitrogen	Co2	Co2
Anti Corrosive Treatment	Phosphating (7 Tanks)	Phosphating (7 Tanks)	Phosphating (7 Tanks)
Painting	Epoxy Polyester Powder Coating	Epoxy Polyester Powder Coating	Epoxy Polyester Powder Coating
Tare Weight (Approx.)	3/4 kg.	4.2/5.6 kg.	37.5 kg.
Gross Weight (Approx.)	9/13 kgs.	10.2/14.6 kgs.	87.5 kgs.



**WATER TYPE
(STORED PRESSURE)
FIRE EXTINGUISHER**

**TECHNICAL
SPECIFICATIONS -
STORED PRESSURE**



MODEL	PRFS SM 6/9	PRFS M 6/9	PRFS M 50
Capacity	6/9 Ltrs	6/9 Ltrs	50 Ltrs
Confirming IS No.	15683	15683	16018
Fire Rating	2A/4A	2A/3A	20A
Operating Temperature	+5 C To + 55°C	+5 C To 55°C	+5 C To 55°C
Min. Jet Length (in mtrs)	6 Mtrs.	6 Mtrs.	10 Mtrs.
Discharge Percentage Min.	95%	95%	95%
Discharge Time Min	13 Seconds	13 Seconds	160 - 180 Seconds
Cylinder	15 kgf/cm ²	-	-
Test Pressure	35 Kgf/cm ²	35 Kgf/cm ²	30 Kgf/cm ²
Operating Valves	Squeeze Grip Type	Squeeze Grip Type	Conventional
Extinguisher Media	Water	Water	Water
Expellant	Dry Nitrogen	Co ²	Co ²
Anti Corrosive Treatment	Phosphating (7 Tanks)	Phosphating (7 Tanks)	Phosphating (7 Tanks)
Painting	Epoxy Polyester Powder Coating	Epoxy Polyester Powder Coating	Epoxy Polyester Powder Coating
Tare Weight (Approx.)	3/4 kgs.	4.2/5.6 kgs.	37.5 kgs.
Gross Weight (Approx.)	9/13 kgs.	10.2/14.6 kgs.	87.5 kgs.

**CLEAN AGENT
FIRE EXTINGUISHER**

**TECHNICAL
SPECIFICATIONS -
ABC STORED PRESSURE**



MODEL	PRFS CA 1/2	PRFS CA 4/6
Capacity	1/2 kg.	4/6 kg.
Confirming IS No.	15683	15683
Fire Rating	8 B/1A, 8 B	1A, 13 B/2A, 34 B
Operating Temperature	-20° C To + 55°C	-20° C To + 55°C
Min. Jet Length (in mtrs)	2Mtrs.	4Mtrs.
Discharge Percentage Min.	85/95%	95%
Discharge Time Min	8/13 Seconds	13 Seconds
Charge Pressure	15 kgf/cm ⁰ /cm ²	15 kgf/cm ²
Test Pressure	35 Kgf/cm ²	35 Kgf/cm ²
Operating Valves	Squeeze Grip Type	Squeeze Grip Type
Extinguisher Media	HFC 236fa	HFC 236fa
Expellant	Dry Nitrogen	Dry Nitrogen
Anti Corrosive Treatment	Phosphating (7 Tanks)	Phosphating (7 Tanks)
Painting	Epoxy Polyester Powder Coating	Epoxy Polyester Powder Coating
Tare Weight (Approx.)	1/1.4 kg.	2.3/3 kg.
Gross Weight (Approx.)	2/3.4 kgs.	6.3/9 kgs.

**DRY POWDER/CLEAN
AGENT MODULAR TYPE
FIRE EXTINGUISHER**

**TECHNICAL
SPECIFICATIONS**



MODEL	PRFS MD 2/5	PRFS MD 10/15
Capacity	2/5 kg.	10/15 kg.
Area Protection in m2	1 - 1.5/3.5 - 4	7 - 8/8-10
Operation Time	8 - 10/10 - 15seconds	1A, 13B/2A, 34 B
Working Pressure	7 to 15 kgf/cm ²	7 to 15 kgf/cm ²
Volume Protection	3m ³ /8m ³	15m ³ /20m ³
Hanging vertically above risk	1.5/1.5 - 2 m	1.75 - 2.2/2-3 m
Operation Temperature	68 ^o C / 79 ^o C / 93 ^o C	68 ^o C / 79 ^o C / 93 ^o C
Test Pressure	35 Kgf/cm ²	35 Kgf/cm ²
Operating Valves	Automatic	Automatic
Propellent	Dry Nitrogen	Dry Nitrogen
Anti Corrosive Treatment	Phosphatting (7 Tanks)	Phosphatting (7 Tanks)
Extinguisher Media	Dry Powder / HFC 236 fa	Dry Powder / HFC 236 fa
Painting	Epoxy Polyester Powder Coating	Epoxy Polyester Powder Coating
Tare Weight (Approx.)	1.9/3.4 kg.	5.2/7.5 kg.
Gross Weight (Approx.)	3.9/8.4 kg.	15.2/22.5 kg.

**DRY POWDER/CLEAN
AGENT MODULAR TYPE
FIRE EXTINGUISHER**

**TECHNICAL
SPECIFICATIONS -
BC/ABC Higher Capacity
Trolley Mounted
Fire Extinguishers**



MODEL	PRFS D 25/50	PRFS D 50
Capacity	25/50 ltrs.	75 kgs.
Confirming IS No.	16018	16018
Fire Rating	233 B	233 B
Operating Temperature	-30 ^o C To +55 ^o C	-30 ^o C To +55 ^o C
Min. Jet Length (in mtrs)	6/8Mtrs.	10Mtrs.
Discharge Percentage Min.	85%	85%
Discharge Time Min	25/40 Seconds	50 Seconds
Charge Pressure	-	-
Test Pressure	30 Kgf/cm ²	30 Kgf/cm ²
Operating Valves	Conventional	Conventional
Extinguisher Media	Dry Powder 14609 / 4308	Dry Powder 14609 / 4308
Expellant	Co2	Co2
Anti Corrosive Treatment	Phosphating (7 Tanks)	Phosphating (7 Tanks)
Painting	Epoxy Polyester Powder Coating	Epoxy Polyester Powder Coating
Tare Weight (Approx.)	29/70 kg.	73.5 kg.
Gross Weight (Approx.)	54/120 kgs.	148.5 kgs.

Fire Extinguisher

			
Stainless Steel Fire Extinguisher	D Class Fire Extinguisher	K Class Fire Extinguisher	M. Foam 135ltr Fire Extinguisher

Gas Suppression System Fire Alarm / Detection Co2/ Clean Agent / Water / Powder / Foam Bladder System



**Co2 Cylinder
Blank**



**Clean Agent Fire
Suppression System**



**Fire Detection
System**



**Fire Hydrant
System**



**Foam Bladder
System**



**Kitchen Fire
Suppression System**

Hydrant Systems

• Sprinkles • Hydrant • Hose Boxes • Fire Hose Reels • Accessories
 Technical Specifications

**Landing Valves :
 Single Outlet ISI Marked (Type 'A')**



Size : Inlet 75/80mm with 63mm size one no. female outlet
 Material : Leaded Tin Bronze of IS:318 and stainless steel - IS:3444
 Performance Test : Hydrostatic (Body Test) Tested at 21 kgf/cm²
 Water Tightness (Seat Test) : Tested at Kgf/cm²
 Flow Test : 900ltr at kgf/cm²

**Landing Valves :
 Double Outlet ISI Marked (Type 'B')**




Size : Inlet 100mm with 63mm size two nos. female outlet
 Material : Leaded Tin Bronze of IS:318 and stainless steel - IS:3444
 Performance Test : Hydrostatic (Body Test) Tested at 21 kgf/cm²
 Water Tightness (Seat Test) : Tested at 14 Kgf/cm²
 Flow Test : 1800 liter at 7 kgf/cm²

Hose Delivery Coupling



Size : 63mm
 Material : Leaded Tin Bronze of IS:318 and stainless steel - IS:3444
 Performance Test : Hydrostatic Test (Body Test) Tested at 21 kgf/cm²
 Other Range : 70mm, 52mm & 38mm

Branch Pipe and Nazzle



Size : 63mm
 Material : Leaded Tin Bronze of IS:318 and stainless steel - IS:3444
 Performance Test : Hydrostatic Test (Body Test) Tested at 21 kgf/cm²
 Other Range : 52mm & 38mm


Fire Hose



Inner Diameter	63mm
Mass Per meter	500 gms max
Burst Pressure	36 bar
Proof Pressure	22 bar
Kink Pressure	22 bar
Working Pressure	18 bar


All size hose available

**Stand Post Type Water Cum foam /
 Water Monitor as per IS : 8442**




Size 63mm
 Material : Seamless Steel Tubes
 Performance Test : Hydrostatic Test (Body Test) : Test at 21 Kgf/cm²
 Discharge at working pressure 7 kgf/cm² : 1700 lt/min
 Range : Vertical 21 meter / Horizontal : 53meter
 Rotation Vertical : 125 0Min. (800 upward and 450 downward)
 Horizontal : 360 in either direction

Rubber / Thermoplastic Hose



General	Nominal Bore	20.0+0.75mm
Type I	Working Pressure	6K Kg/cm ²
	Proof Pressure	12K Kg/cm ²
	Brusting Pressure	19K Kg/cm ²
Type II	Working Pressure	10 K Kg/cm ²
	Proof Pressure	20K Kg/cm ²
	Brusting Pressure	30K Kg/cm ²

First Aid Hose Reel



Size : Inlet 20 mm (3/4" BSP Thread Size)
 Hose Reel Tubing Hydraulic Rubber Hose Conf to IS:444
 Type : Swinging 1800 Wall Mounting
 Performance Test : Hydrostatic Test : Tested at 21 Kgf/cm²
 Range & Water Flow rate test at 7 Kgf/cm²
 (A) Discharge 24 Liter per Minute
 (B) Range (Jet Length) : 6mtr (min)

Fire Hose Box



Material : Mild Steel, Stainless Steel and FRP
 Type : Singel Door / Double Door Type with Locking Arrangement, Front Glass and key

4/3/2 Way Suction Collection Head



Consist of 4/3/2 nos. 63mm Size (GM) Male Instantaneous Coupling as per IS:903 with NRV



Personal Protective Equipments



Safety Helmet



Safety Face Screens



Safety Goggles



Ear Muffs



Organic Vapor
Respirator



Head Cap
(Bouffant Cap)



Dust Mask



Fall Arrest
Harnesses



Nitrile Hand Gloves



Megaphone
P. A. System



Wind Sock



First Aid Kit



Breathing Apparatus
for Fire Fighting



Reflective Jacket



Safety Boot



Electronic Hooter




Addressable Fire
Alarm Panel



Manual Gas
Release Unit



Manual Call Point



Probe Type
Heat Detector



Battery Operated
Smoke Alarm



Panel Operated
Smoke Alarm



Electrical Siren



Pneumatic Valve F



Fire Resistant Door



Gate Valve




Deluge Valve

**Gas Suppression Systems,
Fire Alarm/Detection
Co2/Clean Agent/Water/
Powder/Foam Bladder System**


Clients




 Government of India
Form GST REG-06
[See Rule 10(1)]

Registration Certificate

Registration Number : 27BBQP89955F1Z7

1. Legal Name	MANGAL SHEMI BHASKARAN		
2. Trade Name, if any	PRIYANSHI FIRE SERVICE		
3. Additional trade names, if any	nil		
4. Constitution of Business	Proprietorship		
5. Address of Principal Place of Business	FROUND FLOOR, SHOP NO 3, Golden View Apartment, SECTOR 4A PLOT 66, Kopar Khairane, Navi Mumbai, Thane, Maharashtra, 400709		
6. Date of Liability			
7. Period of Validity	From	23/02/2023	To Not Applicable
8. Type of Registration	Regular		
9. Particulars of Approving Authority	Maharashtra		
Signature			
Name	BABANRAO SHIVAJI TAMBE		
Designation	State Tax Officer		
Jurisdictional Office	KOPAR-KHAIRNE_701		
9. Date of issue of Certificate	23/02/2023		

Note: The registration certificate is required to be prominently displayed at all places of business in the State.

This is a system generated digitally signed Registration Certificate issued based on the approval of application granted on 23/02/2023 by the jurisdictional authority.



Certificate



भारत सरकार
Government of India
सूक्ष्म, लघु एवं मध्यम उद्यम मंत्रालय
Ministry of Micro, Small and Medium Enterprises



UDYAM REGISTRATION CERTIFICATE

UDYAM REGISTRATION NUMBER	UDYAM-MH-33-0242124																				
NAME OF ENTERPRISE	PRIYANSHI FIRE SERVICES																				
TYPE OF ENTERPRISE *	MICRO (Based on FY 2020-21)																				
MAJOR ACTIVITY	SERVICES																				
SOCIAL CATEGORY OF ENTREPRENEUR	GENERAL																				
NAME OF UNIT(S)	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th>S.No.</th> <th>Name of Unit(s)</th> </tr> <tr> <td>1</td> <td>PRIYANSHI FIRE SERVICES</td> </tr> </table>	S.No.	Name of Unit(s)	1	PRIYANSHI FIRE SERVICES																
S.No.	Name of Unit(s)																				
1	PRIYANSHI FIRE SERVICES																				
OFFICIAL ADDRESS OF ENTERPRISE	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th>Flat/Door/Block No.</th> <th>PLOT NO 24</th> <th>Name of Premises/ Building</th> <th>FLAT NO D 101</th> </tr> <tr> <td>Village/Town</td> <td>ARIHANT RIDDHI SIDDHI CHS</td> <td>Block</td> <td>SECTOR 7</td> </tr> <tr> <td>Road/Street/Lane</td> <td>GHANSOLI</td> <td>City</td> <td>NAVI MUMBAI</td> </tr> <tr> <td>State</td> <td>MAHARASHTRA</td> <td>District</td> <td>THANE , Pin 400701</td> </tr> <tr> <td>Mobile</td> <td>9004112158</td> <td>Email:</td> <td>mangalbhaskaran@gmail.com</td> </tr> </table>	Flat/Door/Block No.	PLOT NO 24	Name of Premises/ Building	FLAT NO D 101	Village/Town	ARIHANT RIDDHI SIDDHI CHS	Block	SECTOR 7	Road/Street/Lane	GHANSOLI	City	NAVI MUMBAI	State	MAHARASHTRA	District	THANE , Pin 400701	Mobile	9004112158	Email:	mangalbhaskaran@gmail.com
Flat/Door/Block No.	PLOT NO 24	Name of Premises/ Building	FLAT NO D 101																		
Village/Town	ARIHANT RIDDHI SIDDHI CHS	Block	SECTOR 7																		
Road/Street/Lane	GHANSOLI	City	NAVI MUMBAI																		
State	MAHARASHTRA	District	THANE , Pin 400701																		
Mobile	9004112158	Email:	mangalbhaskaran@gmail.com																		
DATE OF INCORPORATION / REGISTRATION OF ENTERPRISE	01/09/2022																				
DATE OF COMMENCEMENT OF PRODUCTION/BUSINESS	01/09/2022																				
NATIONAL INDUSTRY CLASSIFICATION CODE(S)	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th>SNo.</th> <th>NIC 2 Digit</th> <th>NIC 4 Digit</th> <th>NIC 5 Digit</th> <th>Activity</th> </tr> <tr> <td>1</td> <td>43 - Specialized construction activities</td> <td>4321 - Electrical installation</td> <td>43214 - Installation of fire alarm system and burglar alarm system</td> <td>Manufacturing</td> </tr> </table>	SNo.	NIC 2 Digit	NIC 4 Digit	NIC 5 Digit	Activity	1	43 - Specialized construction activities	4321 - Electrical installation	43214 - Installation of fire alarm system and burglar alarm system	Manufacturing										
SNo.	NIC 2 Digit	NIC 4 Digit	NIC 5 Digit	Activity																	
1	43 - Specialized construction activities	4321 - Electrical installation	43214 - Installation of fire alarm system and burglar alarm system	Manufacturing																	
DATE OF UDYAM REGISTRATION	13/09/2022																				

* In case of graduation (upward/reverse) of status of an enterprise, the benefit of the Government Schemes will be availed as per the provisions of Notification No. S.O. 2119(E) dated 26.06.2020 issued by the M/o MSME.

Disclaimer: This is computer generated statement, no signature required. Printed from <https://udyamregistration.gov.in> & Date of printing:- 15/10/2022

For any assistance, you may contact:

1. District Industries Centre: THANE (MAHARASHTRA)

2. MSME-DFO: MUMBAI (MAHARASHTRA)



Visit : www.msme.gov.in ; www.dcmsme.gov.in ; www.ch

Follow us @minmsme & @msme



CERTIFICATE OF CONFORMITY

It is confirmed that the management system of

PRIYANSHI FIRE SERVICES

PLOT 24, FLAT NO.D 101, ARIHANT RIDDHI SIDDHI CHS, SECTOR 7, GHANSOLI NAVI MUMBAI 400701, INDIA

It has been evaluated and complies with the requirements of

ISO 9001:2015
Quality Management System

This certificate is valid for the following activities


Supply of fire extinguishers & Refilling , fire hydrant & Fire alarm system supply & servicing

Certificate Number: SISTEMA-IND/0223/IPQ16293
Issue date: 11.02.2023
Expiry date: 10.02.2024
Date of First Surveillance: 11.01.2024
Date of second surveillance: 11.01.2025
Recertification date: 11.01.2026

Managing Director

Verify the certificate- www.sistemacerts.com

CERTIFICATE CERTIFICATO CERTIFICATO CERTIFICATO



महाराष्ट्र दुकाने व आस्थापना (नोकरीचे व सेवासंतीचे विनियमन) नियम, २०१८
नमुना "ग"
(नियम ९ पहा)

सूचना दिल्याबाबत पावती

अर्जदाराने नमुना फ द्वारा व्यवसाय सुरु केल्याबाबतची सूचना खाली नमूद केलेल्या तपशीलासह या कार्यालयस दिलेली आहे. त्याचा तपशील पुढीलप्रमाणे:

१. पावती क्रमांक	: २१०२००३१६८६३००८								
२. अर्जाचा (प्रमाणपत्राचा) आयडी क्रमांक	: १०८९१०१२२२३								
३. आस्थापनेचे नाव	: प्रियंशी फायर सर्विसेज PRIYANSHI FIRE SERVICES								
४. कामगारांची एकूण संख्या	: ६								
	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th>पुरुष</th> <th>स्त्री</th> <th>इतर</th> <th>एकूण</th> </tr> <tr> <td>६</td> <td>०</td> <td>०</td> <td>६</td> </tr> </table>	पुरुष	स्त्री	इतर	एकूण	६	०	०	६
पुरुष	स्त्री	इतर	एकूण						
६	०	०	६						
५. अ) मालकाचे नाव	: मंगल भास्करन MANGAL BHASKARAN								
ब) आस्थापनेचा पत्ता	: प्लॉट नं २४, फ्लॉट नं १०१, अरिहंत रिद्धी सिद्धी सीएचएस, रोड नं ७, घानसोली, नवी मुंबई (महानगरपालिका), ठाने, दादणे, ४००७०१								
६. सदरची पावती ही कोवळ अर्जदाराने त्याचा व्यवसाय सुरु केल्याबद्दल कार्यालयास पाठविलेल्या सूचना पत्राची पावती असून व्यवसाय अथवा व्यवसायाची जागा अस्तित्वात असल्याबद्दलचा पुरावा नाही. व्यवसायासाठी व व्यवसायाच्या जागेसाठी आवश्यक असणाऱ्या संबंधित सक्षम प्राधिकारी यांच्याकडील पूर्व / पश्चात परवानगी, अनुज्ञप्ती, परवाना धारण करण्याची सर्वेस्वी जबाबदारी मालकाची राहिल. ही पावती व्यवसायाच्या जागेचा मालकी हक्क किंवा मालतेचा मालकी हक्क किंवा ताबा या प्रयोजनांसाठी कोणत्याही कायदात्मक त्राह्य धरता येणार नाही.									
७. व्यवसायाचे स्वरूप	: FIRE FIGHTING								
८. सूचीचा नोंदणी प्रमाणपत्राचा क्रमांक व दिनांक, लागू असल्यास									

टीप : सदरची पावती सूचक प्रणालीद्वारे तयार करण्यात आलेली असल्याने त्यावर स्वाक्षरीची आवश्यकता नाही. सूचक प्रणालीद्वारे अर्जदाराने सादर केलेल्या स्वयंघोषापत्र आणि स्वयंसाक्षात्कृत अमिलेखाद्वारे पत्रताळणी न करता येण्यात आले आहे.

सादर घोषपावती ही १० पेक्षा कमी कामगार असलेल्या आस्थापनांना नोंदणी दाखल्या ऐवजी देण्यात येते. त्यांना नमुना - ब मध्ये नोंदणी प्रमाणपत्र अनुज्ञेय होत नाही.

दिनांक : १६-०९-२०२२
ठिकाण : Thane
कार्यालयाचा पत्ता : Shop Inspector Office, Vashi, Address- Agarwal Chambers No.२, Sector -१९-C, Vashi, Navi Mumbai.



FORM I-A
Certificate of Enrolment
under sub-section(7) of sub-section (2A) or sub-section (3) of section 5 the Maharashtra State Tax on Professions, Trades, Callings and Employments Act, 1975
(New rule 41(2))

00004713149

Enrolment Certificate Number 99514466639P

This is to certify that, Shri MANGAL SHEMI BHASKARAN whose details are given below has been enrolled under Maharashtra State Tax on Professions, Trades, Callings and Employments Act, 1975.

1. Name of the Enrolled Person: Shri MANGAL SHEMI BHASKARAN

2. Name of Work/Business/Activity (if applicable):

3. Address of person/Principal place of work/Business/Activity: D 101,ARIHANT RIDDHI, RIDDHI SIDDHI,SECTOR 7, Ghansoli, NAVI MUMBAI (M CORP.), THANE, 400701

4. Entry Number under Schedule-I: 020 (A)

5. Address of Additional Place(s) of shop no 3,ground floor, golden view chs,sector 4A, Koper Khairne, NAVI MUMBAI (M CORP.), THANE, 400709

6. Certificate with effect from: 01-Apr-22

The holder of this certificate shall pay the tax for the unenrolled period at Rs. 0.00 immediately for the years 0-0 (Previous years); Rs 2500.00 on or before 16-Mar-23 for year 2022-2023 (current year) and Rs 2500.00 per annum on or before 30th June of every year, in the manner prescribed in rule 20 of the Maharashtra State Tax on Professions, Trades, Callings and Employments Rules, 1975.

Place : Desk ID -

Date : 14-Feb-23

महाराष्ट्र राज्य सरकार
Maharashtra Sales Tax Department





Priyanshi Fire Services

We aim to give fire protection

+91 9004112158 | info@priyanshifireservices.com
Golden View CHS Panchratan Society, Shop No. 3, Plot No 66A,
Sector 4A, KoparKhairane, Navi Mumbai 400 709

Mumbai | Navi Mumbai | Sangli | Belgaum